Features:

- Separate sensors to detect smoke and CO; the two alarm sensors work independently
- Voice with programmable location
- Separate audible and visual signals to indicate alarm levels of smoke or CO
- Wireless interconnect
- Powered by two "AA"
- Side access drawer for easy battery replacer

Printed in Mexico M08-0146-027 **J1** 09/14



p



INTRODUCTION

Thank you for choosing First Alert® for your Smoke and Carbon Monoxide Alarm needs. You have purchased a state-of-the-art Smoke & Carbon Monoxide Alarm designed to provide you with early warning of a smoke and/or Carbon Monoxide danger. Key features include:

Smoke & Carbon Monoxide Combination Alarm. One alarm protects against two deadly household threats.

WIRELESS INTERCONNECT Enabled. Alarm automatically communicates with other WIRELESS INTERCONNECT enabled alarms

Exclusive Voice Warning with Location will tell you the preprogrammed location of the initiating unit and danger detected. Programmable up to 11 locations (ex. "basement"). When alarms sounds, if programmed for basement it will say "Warning, evacuate, smoke in basement" along with all other installed WIRELESS INTERCONNECT Voice alarms.

Spread Spectrum Horn Tone. Lower and varying horn frequency makes it easier for elderly with normal age related hearing loss to hear horn. Sweeps through the 2200 - 3400 Hz range.

RF Interconnect. Reliable and secure radio frequency communication between alarms. 915 MHz frequency with 65,000 security codes and 3 channel frequency hopping.

Single Button Test/Silence eliminates confusion. Depending on what ode the alarm is in, pushing the button provides different functions such as testing the alarm, silencing the alarm, re-testing the alarm when in silence and clearing the Latching features.

Two Silence Features. Temporarily silence low battery chirp for up to eight hours before replacing low battery or silence an unwanted alarm for several minutes.

Two Latching Features. Alarm Latch: Easily identifies initiating alarm even after alarm condition has subsided. Low Battery Latch: Identifies which unit is in low battery condition.

Perfect Mount System includes a gasketless base for easy installation and a mounting bracket that keeps the alarm secure over a wide rotation range to allow for perfect alignment.

End of Life Signal. Provides audible confirmation alarm needs to be

© 2014 BRK Brands, Inc. All rights reserved.

Distributed by BRK Brands, Inc. 3901 Liberty Street Road, Aurora, IL 60504-8122 Consumer Affairs: (800) 323-9005 • www.firstalert.com

All First Alert® Smoke Alarms conform to regulatory requirements, including UL217 and are designed to detect particles of combustion

Smoke particles of varying number and size are produced in all fires. Ionization technology is generally more sensitive than photoelectric technology at detecting small particles, which tend to be produced in greater amounts by flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include

 $\fbox{\textbf{P}}$ Photoelectric technology is generally more sensitive than ionization technology at detecting large particles, which tend to be produced in greater amounts by smoldering fires, which may smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding.

For maximum protection, use both types of Smoke Alarms on each level and in every bedroom of your home

paper burning in a wastebasket, or a grease fire in the kitchen.

WIRELESS OPERATION

First Alert® WIRELESS INTERCONNECT Technology is the easy, cost-effective way to provide your family with whole-home safety. All WIRELESS INTERCONNECT Alarms communicate with each other without wires or connectors. When one Alarm sounds, they all sound. This provides your family with an earlier warning of potential danger, and gives you more time to react.

The communication distance (range) between any two WIRELESS INTERCONNECT Alarms is typically 50 feet (15 meters) inside of a home. Some features of a home, such as the number of floors, number/ size of rooms, furniture and types of building materials used may reduce the range of the Alarms. Examples include: suspended ceilings, ductwork, large metallic appliances (refrigerators) and metal studs. A feature of WIRELESS INTERCONNECT Alarms is that they operate as a mesh network. All Alarms will repeat any alarm signal that is received to all other WIRELESS INTERCONNECT Alarms. Interference from structural conditions can be overcome by adding additional Alarms to route the wireless signal around obstructions

IMPORTANT!

- The range and proper operation of any wireless device will vary depending on its surroundings. It is very important that each Alarm is tested individually before and after installation to make sure that all Alarms respond properly.
- The WIRELESS INTERCONNECT Alarms are not to be used outdoors or to transmit between buildings. The Alarms will not communicate properly under these conditions.
- Metal objects and metallic wallpaper may interfere with signals from wireless Alarms. Alarms should be tested after changes to your home such as remodeling, moving furniture, and with metal doors opened and closed.

Your First Alert® WIRELESS INTERCONNECT Smoke/CO Alarm will automatically communicate both potential fires and carbon monoxide presence with all other First Alert® WIRELESS INTERCONNECTSmoke/

ACAUTION!

Changes or modifications not expressly approved by BRK Brands, Inc. could void the user's authority to operate the equipment.

IMPORTANT! PLEASE READ CAREFULLY AND SAVE.

This user's manual contains important information about your Combination Carbon Monoxide & Smoke Alarm's operation. If you are installing this Alarm for use by others, you must leave this manual—or a copy of it—with the end user.

FIRE SAFETY TIPS

Follow safety rules and prevent hazardous situations: 1) Use smoking materials properly. Never smoke in bed. 2) Keep matches or lighters away from children: 3) Store flammable materials in proper containers: 4) Keep electrical appliances in good condition and don't overload electrical circuits; 5) Keep stoves, barbecue grills, fireplaces and chimneys grease- and debris-free; 6) Never leave anything cooking on the stove unattended; 7) Keep portable heaters and open flames, like candles, away from flammable materials;8) Don't let rubbish accumulate.

Keep alarms clean, and test them weekly. Replace alarms immediately if they are not working properly. Smoke Alarms that do not work cannot alert you to a fire. Keep at least one working fire extinguisher on every floor, and an additional one in the kitchen. Have fire escape ladders or other reliable means of escape from an upper floor in case stairs are

BASIC SAFETY INFORMATION

IMPORTANT!

- Dangers, Warnings, and Cautions alert you to important operating instructions or to potentially hazardous situations Pay special attention to these items.
- This Smoke/CO Alarm is approved for use in single-family

ACAUTION!

 This combination Smoke/Carbon Monoxide Alarm has two separate alarms. The CO Alarm is not designed to detect fire or any other gas. It will only indicate the presence of carbon monoxide gas at the sensor. Carbon monoxide gas may be present in other areas. The Smoke Alarm will only indicate presence of smoke that reaches the sensor. The Smoke Alarm gned to sense gas, heat or flames.

AWARNING!

- This Smoke/CO Alarm cannot operate without working batteries. Removing the batteries for any reason, or failing to replace the batteries at the end of their service life, removes your protection.
- NEVER ignore any alarm. See "If Your Smoke/CO Alarm Sounds" for more information on how to respond to an alarm. Failure to respond can result in injury or death.
- The Silence Features are for your convenience only and will not correct a problem. See "Using the Silence Features" for details. Always check your home for a potential problem after any alarm. Failure to do so can result in injury or death.
- Test this Smoke/CO Alarm once a week. If the Alarm ever fails to test correctly, have it replaced immediately! If the Alarm is not working properly, it cannot alert you to a problem
- This product is intended for use in ordinary indoor locations of family living units. It is not designed to measure CO levels in compliance with Occupational Safety and Health Administration (OSHA) commercial or industrial standards. Individuals with medical conditions that may make them more sensitive to carbon monoxide may consider using warning devices which provide audible and visual signals for carbon monoxide concentrations under 30 ppm. For additional information on carbon monoxide and your medical condition contact your physician.

STEP BY STEP GUIDE TO PROGRAMMING THIS ALARM

FOR FIRST TIME AND WHEN CHANGING BATTERIES

Alarm Will Say:
"Welcome, First Alert Smoke and Carbon Monoxide Alarm."
"No location programmed" if <i>first time</i> or "[Location, example: "Basement"] location programmed" when changing batteries.
"To select location, press and hold test button now."
"To save location, press and hold test button after location is heard." Alarm will speak list of locations (see below).
"[Location, example: "Basement" location saved." If no location is chosen: "No location saved."

choice.

Your Alarm has now been	programmed for the lo	ocation of your choice
Available locations:		
Basement	Kitchen	Child's Bedroom
Living Room	Dining Room	Master Bedroom
Family Room	No Location	Guest Bedroom

Utility Room

ADDING AND LINKING ADDITIONAL WIRELESS

NOTE: Steps 1 through 3 need to be completed within two minutes. If more than two minutes pass, the Green power LED will stop blinking. Simply open the battery drawer of the second Alarm and repeat steps 1 through 3.

 \Rightarrow

1. Insert the batteries into the battery drawer of the **next** Alarm. DO NOT CLOSE THE

INTERCONNECT ALARMS

Press and hold the test

battery drawer.

3. Once you hear the unit chirp,

release the test button. The Green power LED will start to blink indicating the WIRFI FSS INTERCONNECT Alarm is waiting for program data from one of the other setup WIRELESS INTERCONNECT Alarms.

- 4. Press and hold the test button on the first Alarm, until the second Alarm chirps and its Green power LED stops blinking. Then release the test button.
- 5. If you have purchased the hardwired battery back-up WIRELESS INTERCONNECT Alarm, you can now connect the hardwired Alarm by installing the three-wire connector on the ceiling to the Alarm.
- 6. Repeat steps 1-5 for additional WIRELESS INTERCONNECT

You have now successfully linked your new WIRELESS INTERCONNECT Alarms.
To add additional Alarms at a later time, follow steps 1 through 5.

2

WHAT YOU WILL SEE AND HEAR WITH THIS ALARM

Under Normal Operations

Voice: Silent

Horn: Silent

Power/Smoke LED: Flashes Green

CO LED: Off

When You Test the Alarm

Voice: "Testing." Horn: 3 beeps, pause, 3 beeps; Voice: "Warning, evacuate smoke in [Location, example: "Basement"

Smoke LED: Flashes Red in sync with the horn pattern

level was [CO level example: _0_ ppm]"

CO LED: Flashes Red in sync with the horn pattern

Horn: 4 fast beeps, pause, 4 fast beeps; Voice: "Warning, evacuate carbon monoxide in [Location, example "Basement"]. Evacuate." Pause. "Highest carbon monoxide

If Battery Becomes Low

Voice: "Replace battery in [Location, example "Kitchen"]." Repeated Horn: chirps once a minute

Power/Smoke LED: Flashes Green On for 2 seconds/Off for 2 seconds. Low Battery Latch is now engaged. CO LED: Off

If Alarm is Not Operating Properly (MALFUNCTION SIGNAL)

Voice: "Detector error in [Location, example "Kitchen"], please see manual" (refer to Troubleshooting Guide). Repeated every 5 hours

Power/Smoke LED: 3 Flashes approximately once a minute

Alarm has reached its End of Life

CO LED: Off

Smoke is Detected

Voice: "Detector error in [Location, example "Basement"], please see manual." Repeated every 5 hours **Horn:** 5 chirps every minute

Power/Smoke LED: 5 Flashes approximately once a minute CO LED: Off

Alarm Levels of CO are Detected

Voice: "Warning, evacuate carbon monoxide in [Location, example: "Kitchen"]. Evacuate." " Horn: 4 beeps, pause, 4 beeps, voice*

Power/Smoke LED: Off CO LED: During Alarm: Flashes Red in sync with the horn pattern.

After Alarm: Flashes Red On for 2 seconds/Off for 2 seconds. CO Alarm Latch is now engaged. *NOTE: If unit goes into CO alarm, the regular 4 beeps-brief pause cycle will repeat for four minutes. After four minutes, the pause will

increase to one minute.

Voice: "Warning, evacuate smoke in [Location, example: "Kitchen"]. Evacuate."

Horn: 3 beeps, pause, 3 beeps, voice

Power/Smoke LED: During Alarm: Flashes Red in sync with the horn pattern. After Alarm: Flashes Red On for 2 seconds/ Off for 2 seconds. Smoke Alarm Latch is now engaged. CO LED: Off

Smoke Alarm is Silenced	CO Alarm is Silenced
Voice: Silent	Voice: Silent
Horn: Off	Horn: Off
Power/Smoke LED: Flashes Red	Power/Smoke LED: Off
CO LED: Off	CO LED: Flashes Red

INSTALLATION

WHERE TO INSTALL THIS ALARM

Minimum coverage for Smoke Alarms, as recommended by the National Fire Protection Association (NFPA), is one Smoke Alarm on every floor, in every sleeping area, and in every bedroom (See "Regulatory Information For Smoke Alarms" for details on the NFPA recommendations).

For CO Alarms, the National Fire Protection Association (NFPA) recommends that a CO Alarm should be centrally located outside of each separate sleeping area in the immediate vicinity of the bedrooms. For added protection, install additional CO Alarms in each separate bedroom, and on every level of your home.

NOTE: For added protection, install an additional Smoke/CO Alarm at least 15 feet (4.6 meters) away from the furnace or fuel burning heat source where possible. In smaller homes or in manufactured homes where this distance cannot be maintained, install the Alarm as far away as possible from the furnace or other fuel burning source. Installing the Alarm close than 15 feet (4.6 meters) will not harm the Alarm, but may increase the requency of unwanted alarms.

In general, install combination Smoke and Carbon Monoxide Alarms In the hall near every sleeping area. If your home has multiple

- sleeping areas, install a unit in each. If a hall is more than 40 feet (12 meters) long, install a unit at each end. On every level of your home, including finished attics and basements.
- Inside every bedroom, especially if people sleep with the door partly or completely closed.
- At the top of first-to-second floor stairs. At the bottom of the basement stairs.
- For additional coverage, install Alarms in all rooms, halls, and storage areas, where temperatures normally remain between 40° F and 100° F (4.4° C and 37.8° C).

Recommended Placement

SMOKE ALARMS, CO ALARMS, AND COMBO UNITS SMOKE ALARMS BEDROOM BOTH, OR COMBINATION SMOKE/CO ALARMS

SUGGESTED AREAS FOR INSTALLING

- When installing on the wall, the top edge of Smoke Alarms should. be placed between 4 inches (102 mm) and 12 inches (305 mm) from the wall/ceiling line.
- When installing on the ceiling, place the Alarm as close to the center as possible. In either case, install at least 4 inches (102 mm) from where the wall and ceiling meet. See "Avoiding Dead Air Spaces" for more
- information. NOTE: For any location, make sure no door or other obstruction could keep carbon monoxide or smoke from reaching the Alarm.

WHERE THIS ALARM SHOULD NOT BE INSTALLED Do NOT locate this Smoke/CO Alarm:

- In garages, furnace rooms, crawl spaces and unfinished attics Avoid extremely dusty, dirty or greasy areas.
- Where combustion particles are produced. Combustion particles form when something burns. Areas to avoid include poorly ventilated kitchens, garages, and furnace rooms. Keep units at least 20 feet (6 meters) from the sources of combustion particles (stove, furnace, water heater, space heater) if possible. In areas where a 20-foot (6 meter) distance is not possible – in modular, mobile, or smalle homes, for example – it is recommended the Smoke Alarm be placed as far from these fuel-burning sources as possible. The placement recommendations are intended to keep these Alarms at a reasonable distance from a fuel-burning source, and thus reduce "unwanted" alarms. Unwanted alarms can occur if a Smoke Alarm is placed directly next to a fuel-burning source. Ventilate these areas as much as possible.
- Within 5 feet (1.5 meters) of any cooking appliance. In air streams near kitchens. Air currents can draw cooking smoke into the smoke sensor and cause unwanted alarms.
- In extremely humid areas. This Alarm should be at least 10 feet (3 meters) from a shower, sauna, humidifier, vaporizer, dishwasher, laundry room, utility room, or other source of high humidity.
- In direct sunlight. In turbulent air, like near ceiling fans or open windows. Blowing air may prevent CO or smoke from reaching the sensors
- In areas where temperature is colder than 40° F (4.4° C) or hotter than 100° F (37.8° C). These areas include non-airconditioned crawl spaces, unfinished attics, uninsulated or poorly insulated ceilings, porches, and garages.
- In insect infested areas. Insects can clog the openings to the sensing chamber
- Less than 12 inches (305 mm) away from fluorescent lights. Electrical "noise" can interfere with the sensor.
- In "dead air" spaces. See "Avoiding Dead Air Spaces"

AVOIDING DEAD AIR SPACES

"Dead air" spaces may prevent smoke from reaching the Smoke/CO Alarm. To avoid dead air spaces, follow installation

On ceilings, install Smoke/CO Alarms as close to the center of the ceiling as possible. If this is not possible, install the Smoke/CO Alarm at least 4 inches (102 mm) from the wall or corner.


For wall mounting (if allowed by building codes), the top edge of Smoke/CO Alarms should be placed between 4 inches (102 mm) and 12 inches (305 mm) from the wall/ceiling line, below typical "dead air"

On a peaked, gabled, or cathedral ceiling, install first Smoke/CO Alarm within 3 feet (0.9 meters) of the peak of the ceiling, measured horizontally. Additional Smoke/CO Alarms may be required depending on the length, angle, etc. of the ceiling's slope. Refer to NFPA 72 for details on requirements for sloped or peaked ceilings

HOW TO INSTALL THIS ALARM

For quick installation instructions see the "Quick and Easy Guide to Programming Your WIRELESS INTERCONNECT Alarm and Using the

IMPORTANT! This combination Smoke/CO Alarm was designed to be mounted



4 CO Alarm LED

Test/Silence Button

Battery Compartment

Power/Smoke Alarm LED

Tools you will need: pencil, drill

vith 3/16" or 5mm drill bit, Phillips screwdriver, hammer, ACAUTION!

Do not install this unit over an electrical junction box. Air currents around junction boxes can prevent smoke from reaching the sensing chamber and prevent the unit from alarming. Only AC powered units are intended for installation

IMPORTANT!

If you want to lock the battery compartment, or lock the Smoke/CO Alarm to the mounting bracket, please read the "Optional Locking Features" section in the "Quick and Easy Guide to Programming our WIRELESS INTERCONNECT Alarm and Using the Optional Features" attachment before you begin installation

- 1. Hold the mounting bracket against the ceiling (or wall) so the vertical mounting slot is aligned in the 12 o'clock position and trace around the inside of the mounting slots (vertical and horizontal mounting).
- 2. Put the unit where it won't get covered with dust when you drill the 3. Using a 3/16" (5 mm) drill bit, drill a hole through the center of the
- 4. Insert the plastic screw anchors (in the plastic bag with screws) into the holes. Tap the screw anchors gently with a hammer, if necessary, until they are flush with the ceiling or wall.
- 5. Line the mounting bracket up over the plastic screw anchors.
- 6. Screw the mounting bracket to the ceiling or wall through the mounting slots using the two screws provided.
- 7. Attach the Smoke/CO Alarm to the mounting bracket. Line up the guides on the alarm's base with the guides on the mounting bracket. When guides are lined up. turn the base clockwise
- NOTE: Once the Alarm is snapped onto the mounting bracket, you can rotate the Alarm to adjust the

(right) until it snaps into place.

Test the Smoke/CO Alarn See "Weekly Testing" for details.

OPTIONAL LOCKING FEATURES

The optional locking features are designed to prevent unauthorized removal of the batteries or alarm. It is not necessary to activate the locks in single-family households where unauthorized battery or Alarm removal is not a concern.

These Alarms have two separate locking features: one to lock the battery compartment, and the other to lock the

Alarm to the mounting bracket. You can choose to use either feature independently, or use them both

features you use, remove one or both pins from the mounting bracket using needle-nose pliers.

Tools you will need: · Needle-nose pliers · Standard flathead screwdriver. Both locking features use locking pins, which are molded into the mounting bracket. Depending on which locking

IMPORTANT!

To permanently remove either locking pin, insert a flathead screwdriver between the locking pin and the lock, and pry the pin out of the lock.

TO LOCK THE BATTERY COMPARTMENT

Do not lock the battery compartment until you install the batteries and test the Alarm.

IMPORTANT!

If the unit does not alarm during testing, DO NOT lock the battery compartment! Install new batteries and test again. If the Alarm still does

- Using needle-nose pliers, detach one locking pin from the mounting
- 2. After batteries are inserted, then push the locking pin through the hole near the battery door latch on the back of the Alarm.

TO LOCK THE MOUNTING BRACKET

one locking pin from the mounting

Insert the locking pin through the

shown in the diagram.

hole on the back of the Alarm as

When you attach the Alarm to the

head will fit into a notch on the

mounting bracket, the locking pin's



locking pin in lock. 4. Reattach the Alarm to the mounting

IMPORTANT!

When replacing the batteries, always test the Alarm before relocking the battery compartment.

TO UNLOCK THE MOUNTING BRACKET

- 1. Insert a flathead screwdrive into the rectangular cut-out the mounting bracket nearest the locking pin.
- 2. Pry the Alarm away from the bracket pushing up on the screwdriver and turning the Alarm counterclockwise (le



IF YOUR SMOKE/CO ALARM SOUNDS WHAT TO DO FIRST-IDENTIFY THE TYPE OF **ALARM SIGNAL**

Refer to previous section "What You Will See and Hear With This

"ALARM-MOVE TO FRESH AIR" If you hear the CO alarm horn and the CO red light is flashing,

bracket.

AWARNING! Actuation of your CO Alarm indicates the presence of carbon monoxide (CO) which can kill you. In other words, when your CO

move everyone to a source of fresh air. DO NOT remove the batteries!

Alarm sounds, you must not ignore it!

IF THE CO ALARM SOUNDS

- IF THE CO ALARM SIGNAL SOUNDS:
- 1. Operate the Test/Silence button. 2. Call your emergency services, fire department or 911. Write down

the number of your local emergency service here:

- 3. Immediately move to fresh air—outdoors or by an open door or vindow. Do a head count to check that all persons are accounted for. Do not re-enter the premises, or move away from the open door or window until the emergency services responder has arrived, the premises have been aired out, and your CO Alarm remains in its
- normal condition. After following steps 1-3, if your CO Alarm reactivates within a 24-hour period, repeat steps 1-3 and call a qualified appliance technician to investigate for sources of CO from fuel-burning equipment and appliances, and inspect for proper operation of this equipment. If problems are identified during this inspection have the equipment serviced immediately. Note any combustion equipment not inspected by the technician, and consult the manufacturers' instructions, or contact the manufacturers directly, for more information about CO safety and this equipment. Make sure that motor vehicles are not, and have not, been operating in an attached garage or adjacent to the residence. Write down the number of a qualified appliance

AFTER AN ALARM

technician here:

After the emergency responders arrive, the premises aired out, and vour CO Alarm remains in its normal condition, you can check what the highest carbon monoxide level sensed was:


"Highest carbon monoxide level

1. Press & Hold Test Button	"To clear highest carbon monoxic level, press and hold test button now."
Alarm Will Say:	
Press & Hold Test Button, if you would like to clear the highest level sensed.	"Highest carbon monoxide level cleared."
If you would like to keep the highest level in memory, do not press anything.	Alarm will say nothing.

1. Remove the Alarm from the

TO UNLOCK THE BATTERY COMPARTMENT

- mounting bracket. If the unit is locked to the bracket, see the section "To Unlock the Mounting Bracket.
- 2. Insert a flathead screwdriver unde the head of the locking pin, and gently pry it out of the battery compartment lock. (If you plan to relock the battery compartment, save the locking pin.)
- 3. To relock the battery compartment, close the battery door and reinsert
- bracket.



IF THE SMOKE ALARM SOUNDS RESPONDING TO AN ALARM AWARNING

If the unit alarms and you are not testing the unit, it is warning you of a potentially dangerous situation that requires your immediate attention. NEVER ignore any alarm. Ignoring the

- alarm may result in injury or death. Never remove the batteries from a battery operated Smoke/CO Alarm to stop an unwanted alarm (caused by cooking smoke. etc.). Removing batteries disables the alarm so it cannot sense smoke, and removes your protection. Instead open a window or fan the smoke away from the unit. The alarm will reset
- · If the unit alarms get everyone out of the house immediately

WHAT TO DO IN CASE OF FIRE

dressed or collect anything

- Don't panic; stay calm. Follow your family escape plan.
- Feel doors with the back of your hand before opening them. If a door is cool, open it slowly. Don't open a hot door. Keep doors and windows closed, unless you must escape through them.

• Get out of the house as quickly as possible. Don't stop to get

 Cover your nose and mouth with a cloth (preferably damp).
 Take short, shallow breaths. Meet at your planned meeting place outside your home, and do a head count to make sure everybody got out safely

• Never go back inside a burning building for any reason.

• Contact your Fire Department for ideas on making your home

 Call the Fire Department as soon as possible from outside. Give your address, then your name.

AWARNING! Alarms have various limitations. See "General Limitations of Smoke/CO Alarms" for details.

USING THE SILENCE FEATURES AWARNING!

the batteries disables the alarm and removes your protection

Never remove the batteries to quiet an unwanted alarm. Removing

The Silence Feature is intended to temporarily silence the horn while

you identify and correct the problem. Do not use the Silence Feature in emergency situations. It will not correct a CO problem or extinguish The Silence Feature can temporarily quiet an unwanted alarm for several

minutes. You can silence this Smoke/CO Alarm by pressing the Test/ Silence button on the alarm cover for at least 3-5 seconds After the Test/Silence button is released, the Red LED blinks during the

When the CO Alarm When the Smoke Alarm is Silenced The CO Alarm will remain silent The Smoke Alarm will remain for up to 4 minutes. return to normal operation. After 4 minutes, if CO levels remain potentially dangerous the horn will start sounding again. If the smoke has not cleared-or continues to increase-the device will go back into alarm.

3

SILENCING THE LOW BATTERY WARNING

This silence feature can temporarily quiet the low battery warning "chirp' for up to 8 hours. You can silence the low battery warning "chirp" by pressing the Test/Silence button on the alarm cover.

Once the low battery warning "chirp" silence feature is activated, the unit continues to flash the Green light twice a minute for 8 hours. After 8 hours, the low battery "chirp" will resume. Replace the batteries as soon as possible; this unit will not operate without battery power!

To deactivate this feature: Press the Test/Silence button again. The unit will go into Test Mode and the low battery warning will resume (LED flashes and unit sounds "chirp" once a minute).

SILENCING THE END OF LIFE SIGNAL

This silence feature can temporarily quiet the End of Life warning "chirp" for up to 2 days. You can silence the End of Life warning "chirp" by pressing the Test/Silence button. The horn will chirp, acknowledging that the End of Life silence feature has been activated.

After approximately 2 days, the End of Life "chirp" will resume

LATCHING FEATURES

Alarm Latch is activated after an Alarm is exposed to alarm levels of smoke or carbon monoxide. After smoke or CO levels drop below alarm levels, the "Smoke/Power" LED and/or the "CO" Red LED will begin to flash On for 2 seconds/Off for 2 seconds. It will continue to flash or "latch" for about 15 minutes, to give you time to determine which unit

Low Battery Latch is activated when the Alarm is in the "low battery condition". When this occurs, the **Smoke/Power** LED flashes Green On for 2 seconds/Off for 2 seconds for about 15 minutes. This feature is designed to help you identify which Alarm needs to have the battery replaced. Although, the Alarm will sound the low battery chirp approximately once every minute, sometimes during the initial stages of "low battery", the Alarm will chirp in greater intervals than one minute, sometimes up to several hours, until the battery reaches a steady low battery level. This innovative feature eliminates the frustration of waiting for and/or identifying which unit is chirping.

WEEKLY TESTING

AWARNING!

- NEVER use an open flame of any kind to test this unit. You lly damage or set fire to the unit or to your home. The built-in test switch accurately tests the unit's pperation as required by Underwriters Laboratories, Inc. (UL). NEVER use vehicle exhaust! Exhaust may cause permanent damage and voids your warranty.
- DO NOT stand close to the Alarm when the horn is sounding. Exposure at close range may be harmful to your hearing. When testing, step away when horn starts sounding

ACAUTION!

It is important to test this unit every week to make sure it is working properly. Using the test button is the recommended way to test this Smoke/CO Alarm.

You can test this Smoke/CO Alarm by pressing and holding the Test/ Silence button on the Alarm cover until Alarm Voice says "Testing" (typically 3-5 seconds).

During testing, you will see and hear the following sequence

- The Alarm Voice will say "Testing." The Horn will sound 3 beeps, pause, 3 beeps. The Alarm Voice will say "Warning, evacuate smoke in [Location, example: "Kitchen"]. Evacuate." The Power/ Smoke LED flashes Red and the CO LED will be Off.
- Next the Horn will sound 4 beeps, pause, 4 beeps, The Alarm. Voice will say "Warning, evacuate carbon monoxide in [Location, example: "Kitchen"]. Evacuate." The Power/Smoke LED will be Off and the CO LED flashes Red.

If the unit does not alarm, make sure the batteries are correctly installed, and test again. If the unit still does not alarm, replace it immediately.

REGULAR MAINTENANCE

This unit has been designed to be as maintenance-free as possible, but there are a few simple things you must do to keep it working properly.

- Test it at least once a week.
- Clean the Smoke/CO Alarm at least once a month; gently vacuum the outside of the Smoke/CO Alarm using your household vacuum's soft brush attachment. A can of clean compressed air (sold at computer or office supply stores) may also be used. Follow manufacturer instructions for use. Test the Smoke/CO Alarm. Never use water, cleaners or solvents since they may damage the unit.
- If the Smoke/CO Alarm becomes contaminated by excessive dirt, dust and/or grime, and cannot be cleaned to avoid unwanted alarms, replace the unit immediately
- Relocate the unit if it sounds frequent unwanted alarms. See "Where This Alarm Should Not Be Installed" for details.

Choosing a replacement battery:

Your Smoke/CO Alarm requires two standard AA batteries. The following batteries are acceptable as replacements: Duracell MN1500. **These** batteries are available at many local retail stores.

AWARNING!

- Always use the exact batteries specified by this User's Manual. DO NOT use rechargeable batteries. Clean the battery contacts and also those of the device prior to battery installation. Install batteries correctly with regard to polarity (+ and -).
- Please dispose of or recycle used batteries properly, following any local regulations. Consult your local waste management any local regulations. Consum your local regulations. Additional recording organization to find an electronics recording facility in your area. DO NOT DISPOSE OF BATTERIES IN FIRE. BATTERIES MAY EXPLODE OR LEAK.


AWARNING!

Keep battery out of reach of children. In the event a battery is swallowed, immediately contact your poison control center, your physician, or the National Battery Ingestion hotline at 202-625-3333 as serious injury may occur.

Actual battery service life depends on the Smoke/CO Alarm and the environment in which it is installed. All the batteries specified above are acceptable replacement batteries for this unit. Regardless of the manufacturer's suggested battery life, you MUST replace the battery immediately once the unit starts "chirping" (the "low battery warning").

To replace the batteries (without removing Alarm from

- 1. Open the battery compartment.
- Press tabs A and B as shown in the diagram and remove each battery.
- 3. Insert the new batteries, making sure they snap completely into the battery compartment. Match the terminals on the ends of the batteries with the
- 4. Close the battery compartment, and then test the unit by pressing the Test/Silence button



WHAT YOU NEED TO KNOW ABOUT CO

CO is an invisible, odorless, tasteless gas produced when fossil fuels do not burn completely, or are exposed to heat (usually fire). Electrical appliances typically do not produce CO.

These fuels include: Wood, coal, charcoal, oil, natural gas, gasoline, kerosene, and propane.

Common appliances are often sources of CO. If they are not properly maintained, are improperly ventilated, or malfunction, CO levels can rise quickly. CO is a real danger now that homes are more energy efficient. "Air-tight" homes with added insulation, sealed windows, and other weatherproofing can "trap" CO inside.

SYMPTOMS OF CO POISONING

These symptoms are related to CO POISONING and should be discussed with ALL household members.

Mild Exposure: Slight headache, nausea, vomiting, fatigue ("flu-like"

Medium Exposure: Throbbing headache, drowsiness, confusion, fast Extreme Exposure: Convulsions, unconsciousness, heart and lung

failure. Exposure to Carbon Monoxide can cause brain damage, death. **IMPORTANT!**

This CO Alarm measures exposure to CO over time. It alarms if CO levels are extremely high in a short period of time, or if CO levels reach a certain minimum over a long period of time. The CO Alarm generally sounds an alarm before the onset of symptoms in average, healthy adults. Why is this important? Because you need to be warned of a potential CO problem while you can still react in time. In many reported cases of CO exposure, victims may be aware that they are not feeling well, but become disoriented and can no longer react well enough to well, but become discribed and carried only only the building or get help. Also, young children and pets may be the first affected. The average healthy adult might not feel any symptoms when the CO Alarm sounds. However, people with cardiac or respiratory problems, infants, unborn babies, pregnant mothers, or elderly people can be more quickly and severely affected by CO. If you experience even mild symptoms of CO poisoning, consult your doctor immediately!


FINDING THE SOURCE OF CO AFTER AN ALARM

Carbon monoxide is an odorless, invisible gas, which often makes it difficult to locate the source of CO after an alarm. These are a few of the factors that can make it difficult to locate sources of CO:

- · House well ventilated before the investigator arrives.
- Problem caused by "backdrafting."
- Transient CO problem caused by special circumstances.

Because CO may dissipate by the time an investigator arrives, it may be difficult to locate the source of CO. BRK Brands, Inc. shall not be obligated to pay for any carbon monoxide investigation or service

POTENTIAL SOURCES OF CO IN THE HOME



Fuel-burning appliances like: portable heater, gas or wood burning fireplace, gas kitchen range or cooktop, gas clothes dryer.

Damaged or insufficient venting: corroded or disconnected water heater vent pipe, leaking chimney pipe or flue, or cracked heat exchanger, blocked or clogged chimney opening.

Improper use of appliance/device: operating a barbecue grill or vehicle in an enclosed area (like a garage or screened porch).

Transient CO Problems: "transient" or on-again-off-again CO problems can be caused by outdoor conditions and other special circumstances.

The following conditions can result in transient CO situations

- Excessive spillage or reverse venting of fuel appliances caused by outdoor conditions such as:
- Wind direction and/or velocity, including high, gusty winds. Heavy air in the vent pipes (cold/humid air with extended periods between cycles).
- Negative pressure differential resulting from the use of exhaust
- Several appliances running at the same time competing for limited fresh air.
- · Vent pipe connections vibrating loose from clothes dryers, furnaces, or water heaters.
- Obstructions in or unconventional vent pipe designs which can amplify the above situations.
- Extended operation of unvented fuel burning devices (range, oven,
- 3. Temperature inversions, which can trap exhaust close to the ground 4. Car idling in an open or closed attached garage, or near a home.

These conditions are dangerous because they can trap exhaust in your home. Since these conditions can come and go, they are also hard to recreate during a CO investigation.

HOW CAN I PROTECT MY FAMILY FROM

CO POISONING?

A CO Alarm is an excellent means of protection. It monitors the air and sounds a loud alarm before Carbon Monoxide levels become threatening for average, healthy adults.

A CO Alarm is not a substitute for proper maintenance of home

To help prevent CO problems and reduce the risk of CO poisoning:

- Clean chimneys and flues yearly. Keep them free of debris, leaves, and nests for proper air flow. Also, have a professional check for rust and corrosion, cracks, or separations. These conditions can prevent proper air movement and cause backdrafting. Never "cap" or cover a chimney in any way that would block air flow.
- Test and maintain all fuel-burning equipment annually. Many local gas or oil companies and HVAC companies offer appliance inspections for a nominal fee.
- Make regular visual inspections of all fuel-burning appliances Check appliances for excessive rust and scaling. Also check the flame on the burner and pilot lights. The flame should be blue. A yellow flame means fuel is not being burned completely and CO may be present. Keep the blower door on the furnace closed. Use vents or fans when they are available on all fuel-burning appliances. Make sure appliances are vented to the outside. Do not grill or barbecue indoors, or in garages or on screen porches.
- Check for exhaust backflow from CO sources. Check the draft hood on an operating furnace for a backdraft. Look for cracks on furnace heat exchangers.
- Check the house or garage on the other side of shared wall.
- Keep windows and doors open slightly. If you suspect that CO is escaping into your home, open a window or a door. Opening windows and doors can significantly decrease CO levels.

In addition, familiarize yourself with all enclosed materials. Read this manual in its entirety, and make sure you understand what to do if your CO Alarm sounds.

REGULATORY INFORMATION FOR SMOKE/CO ALARMS

REGULATORY INFORMATION FOR CO ALARMS WHAT LEVELS OF CO CAUSE AN ALARM?

Underwriters Laboratories Inc. Standard UL2034 requires residential CO Alarms to sound when exposed to levels of CO and exposure times a described below. They are measured in parts per million (ppm) of CO over time (in minutes).

UL2034 Required Alarm Points*:

- If the alarm is exposed to 400 ppm of CO, IT MUST ALARM BETWEEN 4 and 15 MINUTES.
- If the alarm is exposed to 150 ppm of CO, IT MUST ALARM BETWEEN 10 and 50 MINUTES.
- If the alarm is exposed to 70 ppm if CO, IT MUST ALARM BETWEEN 60 and 240 MINUTES.

* Approximately 10% COHb exposure at levels of 10% to 95% Relative Humidity (RH). The unit is designed not to alarm when exposed to a constant level

of 30 ppm for 30 days.

- CO Alarms are designed to alarm before there is an immediate life threat. Since you cannot see or smell CO, never assume it's not present.
- An exposure to 100 ppm of CO for 20 minutes may not affect average, healthy adults, but after 4 hours the same level may cause headaches.
- An exposure to 400 ppm of CO may cause headaches in average, healthy adults after 35 minutes, but can cause death after 2 hours. Standards: Underwriters Laboratories Inc. Single and Multiple Station carbon monoxide alarms UI 2034

According to Underwriters Laboratories Inc. UL2034, Section 1-1.2: "Carbon monoxide alarms covered by these requirements are intended to respond to the presence of carbon monoxide from sources such as, but not limited to, exhaust from internal-combustion engines, abnormal operation of fuel-fired appliances, and fireplaces. CO Alarms are intended to alarm at carbon monoxide levels below those that could cause a loss of ability to react to the dangers of Carbon Monoxide exposure." This CO Alarm monitors the air at the Alarm, and is designed to alarm before CO levels become life threatening. This allows you precious time to leave the house and correct the problem. This is only possible if Alarms are

located, installed, and maintained as described in this manual. Gas Detection at Typical Temperature and Humidity Ranges: The CO Alarm is not formulated to detect CO levels below 30 ppm typically UL tested for false alarm resistance to Methane (500 ppm). Butane (300 ppm), Heptane (500 ppm), Ethyl Acetate (200 ppm), Isopropyl Alcoho (200 ppm) and Carbon Dioxide (5000 ppm). Values measure gas and vapor concentrations in parts per million

Audible Alarm: 85 dB minimum at 10 feet (3 meters).

REGULATORY INFORMATION FOR SMOKE ALARMS RECOMMENDED LOCATIONS FOR SMOKE ALARMS


Installing Smoke Alarms in Single-Family Residences The National Fire Protection Association (NFPA), recommends one Smoke Alarm on every floor, in every sleeping area, and in every bedroom. In new construction, the Smoke Alarms must be AC powered and interconnected. See "Agency Placement Recommendations" for details. For additional coverage, it is recommended that you install a Smoke Alarm in all rooms, halls, storage areas, finished attics, and pasements, where temperatures normally remain between 40° F (4.4° C) and 100° F (37.8° C). Make sure no door or other obstruction could kéep smoke from reaching the Smoke Alarms.

More specifically, install Smoke Alarms:

- On every level of your home, including finished attics and
- Inside every bedroom, especially if people sleep with the door partly or completely closed.
- In the hall near every sleeping area. If your home has multiple sleeping areas, install a unit in each. If a hall is more than 40 feet long (12 meters), install a unit at each end.
- At the top of the first-to-second floor stairway, and at the bottom of

IMPORTANT!

Specific requirements for Smoke Alarm installation vary from state to state and from region to region. Check with your local Fire Departn rent requirements in your area. **It is recommended AC or AC** DC units be interconnected for added protection.



AGENCY PLACEMENT RECOMMENDATIONS

NFPA 72 Chapter 29

"For your information, the National Fire Alarm and Signaling Code NFPA 72, reads as follows:"

29.5.1* Required Detection.

along a path of travel

29.5.1.1* Where required by other governing laws, codes, or standards

for a specific type of occupancy, approved single and multiple-station smoke alarms shall be installed as follows: (1)*In all sleeping rooms and guest rooms (2)*Outside of each separate dwelling unit sleeping area, within 21 ft (6.4 m) of any door to a sleeping room, with the distance measured

- (3) On every level of a dwelling unit, including basements
- (4) On every level of a residential board and care occupancy (small acility), including basements and excluding crawl spaces and unfinished attics

(5)*In the living area(s) of a guest suite

(6) In the living area(s) of a residential board and care occupancy (small facility)

(Reprinted with permission from NFPA 72®, National Fire Alarm and Signaling Code Copyright © 2010 National Fire Protection Association, Quincy, MA 02269. This reprinted material is not the complete and official position of the National Fire Protection Association, on the eferenced subject which is represented only by the standard in its entirety), (National Fire Alarm and Signaling Code® and NFPA 72® are registered trademarks of the National Fire Protection Association, Inc.

California State Fire Marshal (CSFM)

Early warning detection is best achieved by the installation of fire detection equipment in all rooms and areas of the household as follows: A Smoke Alarm installed in each separate sleeping area (in the vicinity, but outside bedrooms), and Heat or Smoke Alarms in the living rooms, dining rooms, bedrooms, kitchens, hallways, finished attics, furnace rooms, closets, utility and storage rooms, basements, and attached

ABOUT SMOKE ALARMS

Battery (DC) operated Smoke Alarms: Provide protection even when electricity fails, provided the batteries are fresh and correctly installed. Units are easy to install, and do not require professional installation. AC powered Smoke Alarms: Can be interconnected so if one unit senses smoke, all units alarm. They do not operate if electricity fails. AC with battery (DC) back-up: will operate if electricity fails, provided the batteries are fresh and correctly installed. AC and AC/DC units must be installed by a qualified electrician.

WIRELESS INTERCONNECT Smoke Alarms with battery (DC) backup: Interconnects with all WIRELESS INTERCONNECT enabled Smoke and Smoke/CO Alarms without wires or connectors, so when one alarm sounds, they all sound. Will operate if electricity fails, provided the batteries are fresh and correctly installed. Units are easy to install, and do not require professional installation.

Smoke/CO Alarms for Solar or Wind Energy users and battery backup power systems: AC powered Smoke/CO Alarms should only be operated with true or pure sine wave inverters. Operating this Alarm with most battery-powered UPS (uninterruptible power supply) products or square wave or "quasi sine wave" inverters will damage the Alarm.

If you are not sure about your inverter or UPS type, please consult with the manufacturer to verify.

Smoke Alarms for the hearing impaired: Special purpose Smoke Alarms should be installed for the hearing impaired. They include a visual alarm and an audible alarm horn, and meet the requirements of the Americans With Disabilities Act. Can be interconnected so if one unit senses smoke, all units alarm.

Smoke alarms are not to be used with detector guards unless the combination has been evaluated and found suitable for that purpose All these Smoke Alarms are designed to provide early warning of fires if located, installed and cared for as described in the user's manual and if smoke reaches the Alarm. If you are unsure which type of unit to install, refer to National Fire Protection Association (NFPA) 72 (National Fire Alarm and Signaling Code) and NFPA 101 (Life Safety Code) National Fire Protection Association, One Batterymarch Park, Quincy, MA 02269-9101. Local building codes may also require specific units in new construction or in different areas of the home

SPECIAL COMPLIANCE CONSIDERATIONS

This Smoke Alarm is suitable for use in apartments, condominiums, townhouses, hospitals, day care facilities, health care facilities, boarding nouses, group homes and dormitories provided a primary fire detection system already exists to meet fire detection requirements in common areas like lobbies, hallways, or porches. Using this Smoke Alarm in common areas may not provide sufficient warning to all residents or meet local fire protection ordinances/regulations.

This Smoke Alarm alone is not a suitable substitute for complete fire detection systems in places housing many people—like apartment buildings, condominiums, hotels, motels, domitories, hospitals, healt care facilities, nursing homes, day care facilities, or group homes of any kind. It is not a suitable substitute for complete fire detection systems in warehouses, industrial facilities, commercial buildings, and specialpurpose non-residential buildings which require special fire detection and alarm systems. Depending on the building codes in your area, this Smoke Alarm may be used to provide additional protection in these facilities.

In new construction, most building codes require the use of AC or AC/ DC powered Smoke Alarms only. In existing construction, AC, AC/DC, or DC powered Smoke Alarms can be used as specified by local building codes. Refer to NFPA 72 (National Fire Alarm and Signaling Code) and NFPA 101 (Life Safety Code), local building codes, or consult your Fire Department for detailed fire protection requirements in buildings not defined as "households"

HUD MAP Program

Certain HUD battery powered Smoke Alarm applications, especially those that fall under HUD 223(f) MAP (Multi-family Accelerated Processing), may require a 10 Year sealed tamper resistant battery. This alarm does not meet that requirement. Substitute First Alert SA340B.

FCC Compliance

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used n accordance with the instructions, may cause harmful interference to radio communications

However, there is no guarantee that the interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver. Connect the equipment into an outlet on a circuit different from that
- Warning: Changes or modifications to the product, not expressly oved by First Alert / BRK Brands, Inc., could void the user's authority to operate the equipment.

Consult the dealer or an experienced radio or TV technician for help.

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation. FCC ID: M7U5001L

GENERAL LIMITATIONS OF SMOKE/CO ALARMS

This Smoke/CO Alarm is intended for residential use. It is not intended or use in industrial applications where Occupational Safety and Healt Administration (OSHA) requirements for Carbon Monoxide Alarms must be met. The Smoke Alarm portion of this device is not intended to alert hearing impaired residents. Special purpose Smoke Alarms should be installed for hearing impaired residents (CO Alarms are not yet available

Smoke/CO Alarms may not waken all individuals. Practice the escape plan at least twice a year, making sure that everyone is involved – from kids to grandparents. Allow children to master fire escape planning and practice before holding a fire drill at night when they are sleeping If children or others do not readily waken to the sound of the Smoke/CO Alarm, or if there are infants or family members with mobility lir make sure that someone is assigned to assist them in fire drill and in the event of an emergency. It is recommended that you hold a fire drill while family members are sleeping in order to determine their response to the sound of the Smoke/CO Alarm while sleeping and to determine whether they may need assistance in the event of an emergency.

Smoke/CO Alarms cannot work without power. Battery operated units cannot work if the batteries are missing, disconnected or dead, if the wrong type of batteries are used, or if the batteries are not installed correctly. AC units cannot work if the AC power is cut off for any reason (open fuse or circuit breaker, failure along a power line or at a power station, electrical fire that burns the electrical wires, etc.). If you are concerned about the limitations of battery or AC power, install both types of units. This Smoke/CO Alarm will not sense smoke or CO that does not

Smoke or CO may be present in other areas. Doors or other obstructions may affect the rate at which CO or smoke reaches the sensors. If bedroom doors are usually closed at night, we recommend you nstall an alarm device (Combination CO and Smoke Alarm, or separate CO Alarms and Smoke Alarms) in each bedroom and in the hallway between them. This Smoke/CO Alarm may not sense smoke or CO on another level

reach the sensors. It will only sense smoke or CO at the sensor.

of the home. Example: This alarm device, installed on the second floor, may not sense smoke or CO in the basement. For this reason, one alarm device may not give adequate early warning.

Recommended minimum protection is one alarm device in every sleeping area, every bedroom, and on every level of your home. Some experts recommend battery powered Smoke and CO Alarms be used in conjunction with interconnected AC powered Smoke Alarms. For details, see "About Smoke Alarms" for details.

Smoke/CO Alarms may not be heard. The alarm horn loudness meets or exceeds current UL standards of 85 dB at 10 feet (3 meters). However, if the Smoke/CO Alarm is installed outside the bedroom, it may not wake up a sound sleeper or one who has recently used drugs or has been drinking alcoholic beverages. This is especially true if the door is closed or only partly open. Even persons who are awake may not hear the alarm horn if the sound is blocked by distance or closed doors. Noise from traffic, stereo, radio, television, air conditioner, or other appliances ma also prevent alert persons from hearing the alarm horn. This Smoke/CO Alarm is not intended for people who are hearing impaired.

The Alarm may not have time to alarm before the fire itself causes

any way that they will protect lives. Homeowners and renters must still

damage, injury, or death, since smoke from some fires may not reach the unit immediately. Examples of this include persons smoking in bed, children playing with matches, or fires caused by violent explosions resulting from escaping gas This Smoke/CO Alarm is not a substitute for life insurance. Though this Smoke/CO Alarm warns against increasing CO levels or the presence of smoke, BRK Brands, Inc. does not warrant or imply in

This Smoke/CO Alarm has a limited life. Although this Smoke/CO Alarm and all of its parts have passed many stringent tests and are designed to be as reliable as possible, any of these parts could fail at any time. Therefore, you must test this device weekly. The unit should be replaced immediately if it is not operating properly. All Smoke/CO Alarms need to be replaced every 7 years. All Smoke Alarms need to

be replaced every 10 years.

This Smoke/CO Alarm is not foolproof. Like all other electronic devices, this Smoke/CO Alarm has limitations. It can only detect smoke or CO that reaches the sensors. It may not give early warning of the source of smoke or CO is in a remote part of the home, away from the

TROUBLESHOOTING GUIDE Problem.. You should... If the Alarm... Horn "chirps" about once per minute; **Voice:** "Replace battery in [Location]" every 5 Low battery warning Install two new AA batteries* hours Horn sounds 3 "chirps" every minute; Voice: "Detector error in [Location, example Units under warranty should be returned to MALFUNCTION SIGNAL. Device is not working nanufacturer for replacement. See "Limited properly, and needs to be replaced. "Kitchen"], please see manual" repeated every Warranty" for details. 5 hours; LED has 3 flashes with "chirps" The light flashes (RED) and the horn sounds 5 nmediately replace the Alarm. END OF LIFE SIGNAL. "chirps" every minute: Alarm needs to be replaced Voice: "Detector error in [Location, example 'Basement"], please see manual" repeated every 5 hours. The Alarms are linked but do not communicate Operation section of this manual Alarms to route the signal around obstructions with each other. Move Alarms to different locations. Add an Carbon Monoxide Alarm ONLY: IF YOU ARE FEELING SYMPTOMS OF CO CO Alarm goes back into alarm 4 minutes after CO levels indicate a potentially dangerous POISONING, EVACUATE your home and call 911 or the Fire Department. Refer to "If The CO Alarm Sounds" for details. Relocate your Alarm. If frequent alarms continue, have home rechecked for potential CO Alarm sounds frequently even though no high The CO Alarm may be improperly located. Refer to "Where to Install This Alarm" for details. levels of CO are revealed in an investigation CO problems. You may be experiencing an termittent CO problem. Smoke Alarm ONLY: Smoke Alarm sounds when no smoke is visible. Unwanted alarm may be caused by nor Alarm's cover with a soft, clean cloth. If frequent emergency source like cooking smoke. unwanted alarms continue, relocate vour Alarm. Alarm may be too close to a kitchen, cooking appliance, or steamy bathroom. Silence Alarm using manual button; clean the *For a list of acceptable replacement batteries, see "Regular Maintenance."

LIMITED WARRANTY

If you have questions that cannot be answered by reading this manual, call Consumer Affairs at 1-800-323-9005, M-F 7:30 a.m. to 5:00 p.m. (CST)

BRK Brands, Inc., ("BRK") the maker of First Alert® brand products warrants that for a period of seven years from the date of purchase, this produc will be free from defects in material and workmanship. BRK, at its option, will repair or replace this product or any component of the product found to be defective during the warranty period. Replacement will be made with a new or remanufactured product or component. If the product is no longer vailable, replacement may be made with a similar product of equal or greater value. This is your exclusive warranty.

This warranty is valid for the original retail purchaser from the date of initial retail purchase and is not transferable. Keep the original sales receipt. Proof of purchase is required to obtain warranty performance. BRK dealers, service centers, or retail stores selling BRK products do not have the right to alter, modify or any way change the terms and conditions of this warranty.

This warranty does not cover normal wear of parts or damage resulting from any of the following: negligent use or misuse of the product, use on improper voltage or current, use contrary to the operating instructions, disassembly, repair or alteration by anyone other than BRK or an authorized service center. Further, the warranty does not cover Acts of God, such as fire, flood, hurricanes and tornadoes or any batteries that are included with this unit. BRK shall not be liable for any incidental or consequential damages caused by the breach of any express or implied warranty. Except to the extent prohibited by applicable law, any implied warranty of merchantability or fitness for a particular purpose is limited in duration to the duration of the above warranty. Some states, provinces or jurisdictions do not allow the exclusion or limitation of incidental or consequential damages or limitations on how long an implied warranty lasts, so the above limitations or exclusion may not apply to you. This warranty gives you specific legal rights, and you may

so have other rights that vary from state to state or province to province. How to Obtain Warranty Service

Service: If service is required, do not return the product to your retailer. In order to obtain warranty service, contact the Consumer Affairs Division at 1-800-323-9005, 7:30 AM - 5:00 PM Central Standard Time, Monday through Friday. To assist us in serving you, please have the model number and date of purchase available when calling

For Warranty Service return to: BRK Brands, Inc., 25 Spur Drive, El Paso, TX 79906 Battery: BRK Brands, Inc. make no warranty, express or implied, written or oral, including that of merchantability or fitness for any particular purpose with respect to battery.

For your records, ple	ease record:		
Date Purchased:			
Where Purchased: _			
Date Installed:	/	N	/lonth/Year
Replace alarm 7 year the space provided:	rs after install	ation. Pl	lease write the date in
		_/	Month/Year
The alarm will also p approximately 7 year replace the unit.			
The End-of-Life Sign	al can be sile	nced for	un to 2 days

Do not unplug the alarm or remove the batteries until you get replacement.

11

First Alert® is a registered trademark of the First Alert Trust used

Printed in Mexico M08-0146-027 **J1** 09/14 12